



Pendulum Slip Test Certification

Surface Consultants Ltd,
Icon Business Park, 4100 Park Approach,
Thorpe Park, Leeds, LS15 8GB.

niel@surfaceconsultants.co.uk
info@surfaceconsultants.co.uk
Tel - 01977350888


For:

Grafityp UK Limited
Grafitack House, 103 Mariner,
Tamworth
B79 7UL.

Date certificate was prepared: May 18th 2021

Test Date: May-08th -2021

The Grafityp product listed below was tested in accordance with standard Pendulum Slip Test in accordance with BS 7976-2 / UKSRG Guidelines.

Surface Consultants Invoice Number: INV 0012		Customer PO Number: 16199	Customer Sample Identification: WALKWAY-AL R12 ANTI-SLIP FILM
Product Sample: 	Product Description: WALKWAY-AL R12 ANTI-SLIP FILM INDOOR/OUTDOOR Thickness 275 um. Widths 1370mm. Aluminum Backed strong permanent adhesive for use on Brick Asphalt or concrete		
Shelf Life: N/A	Condition for this Product Sample when tested: New Clean		
For Full Test Results: Refer to report 08-05-21	Test Results: >36 PTV When Dry.Low Risk Classification >36 PTV When Wet.Low Risk Classification		
Date of Manufacture: May 2021		Test Location: Unit 28 Ripley Business Centre, Ripley Drive Normanton, W Yorkshire, WF6 1QT	



Sample 001